

City of Appleton

Meeting Agenda - Final

Board of Building Inspection

Wednesday, September 15, 2021	3:00 PM	6th Floor Council Chambers	

- 1. Call meeting to order
- 2. Roll call of membership
- 3. Approval of minutes from previous meeting

<u>21-1312</u> Minutes from August 2, 2021

Attachments: Minutes 8-2-21.pdf

4. Public Hearings/Appearances

5. Action Items

5300 N. Meade St. (31-1-8500-00) The Applicant is proposing to construct an athletic storage building with the stair riser height to be 8" and the tread depth to be 9". Section 4-136 of the Municipal Code (IBC 1011.5.2 of the Commercial Code) requires riser height to be a maximum of 7" and tread depth to be a minimum of 11".

Attachments: 5300 N. Meade St.pdf

6. Information Items

7. Adjournment

Notice is hereby given that a quorum of the Common Council may be present during this meeting, although no Council action will be taken.

Reasonable Accommodations for Persons with Disabilities will be made upon Request and if Feasible.



÷

City of Appleton

100 North Appleton Street Appleton, WI 54911-4799 www.appleton.org

Meeting Minutes - Final Board of Building Inspection

Monday, August 2, 2021		4:00 PM		6th Floor Council Chambers	
1.	Call meeting to	order			
		Mayor Woodford called the meeting to	order at 4:02pm.		
2.	Roll call of men	bership			
	-	Ross Buetow came as a representative Patterson came as a representative of resent: 5 - Public Works Director Van Alderperson Doran and Ba	Battalion Fire Chief Henson. dehey, City Attorney Behrens	6	
3.	Approval of minutes from previous meeting				
	<u>21-1066</u>	Minutes from June 21, 2021			
		Attachments: Minutes 6-21-21.pdf	λ		
		A motion was made by Alderperson I Representative of Battalion Fire Chie be approved. Roll Call. The motion ca	f Battalion Chief Henson, th	nat the minutes	
		Aye: 5 - Public Works Director Van Alderperson Doran and Ba	dehey, City Attorney Behrens ttalion Fire Chief Henson	s, Mayor Woodford,	
4.	Public Hearing	olic Hearings/Appearances			
5.	Action Items				
	<u>21-1067</u>	543 N. Union St. (31-1-0186-00) construct a landing that is 32" wid to be 36" wide.	an Anna an An		
		Attachments: 543 N. Union St.pdf			
		Alderperson Doran moved, seconded Fire Chief Henson, that the Report Ac carried by the following vote:			

Aye: 5 - Public Works Director Vandehey, City Attorney Behrens, Mayor Woodford, Alderperson Doran and Battalion Fire Chief Henson 1

6. Information Items

7. Adjournment

A motion was made by City Attorney Behrens, seconded by Patterson, Representative of Battalion Fire Chief Henson, that this meeting be adjourned at 4:14pm. The motion carried by the following vote:

Aye: 5 - Public Works Director Vandehey, City Attorney Behrens, Mayor Woodford, Alderperson Doran and Battalion Fire Chief Henson Return to:

Department of Public Works Inspection Division 100 North Appleton Street Appleton, Wisconsin 54911 (920) 832-6411

9/15/21 3:00

City of Appleton Application for Board of Building Inspection

Meeting Date:

31-1-8500-00

Please write legibly and also submit a complete reproducible plan (maximum size 11" x 17"). A complete plan includes, but is not limited to, all structures, lot lines and streets with distances to each. There is a non-refundable \$45.00 fee for each variance application. The non-refundable fee is payable to the City of Appleton and due at the time the application is submitted.

Property Information	distant Mar
Addrees of Property (Variance Dominated) D	10.22 3 22 28 2 3 2 2 2
53.00 M m EADE ST	
Zoning District	12157751258126
Pi	1aL

和的影响的影响影响	Applicant Information
Owner Name	Owner Address
tox VALLES LUTH	teran Hichschar 5300 N MEADE ST
Owner Phone Numbe	er
920-1739-44	440
Agent Name	Agent Address
SELLE CUSTON !! !	
Dougiserve	NEW 42WOW, W/ 54961
Agent Phone Number	
11.920-470-4804	dougselle @ g mail.com

Municipal Code Section(s) Project Does not Comply

COMMERCIAL STAIR 7/11

Brief Description of Proposed Project ATHLETIC STORAGE BUILDWG

Owner's Signature (Required):

Doughelle Date: 9/8/2021 MMD John FVL President 9/8/2 Jeffrey I Loberger





