

City of Appleton

Meeting Agenda - Final

Board of Building Inspection

Thursday, January 6, 2022	3:00 PM	6th Floor Council Chambers

- 1. Call meeting to order
- 2. Roll call of membership
- 3. Approval of minutes from previous meeting
 - <u>21-1738</u> Minutes from September 15, 2021

Attachments: Minutes 9-15-21.pdf

4. Public Hearings/Appearances

5. Action Items

21-1739 101 W. Edison Ave (31-4-0257-00) The applicant is requesting a variance be granted to not install automatic sprinklers as required in the SPS 362.0903(2) (as adopted by Section 4-136 of the Municipal Code) for a space that will be used as an A-2 use group, where alcohol will be consumed and the occupant load is limited to 200 persons.

Attachments: 101 W. Edison Ave.doc

6. Information Items

7. Adjournment

Notice is hereby given that a quorum of the Common Council may be present during this meeting, although no Council action will be taken.

Reasonable Accommodations for Persons with Disabilities will be made upon Request and if Feasible.



City of Appleton

100 North Appleton Street Appleton, WI 54911-4799 www.appleton.org

Meeting Minutes - Final Board of Building Inspection

Wednesday, September 15, 2021		3:00 PM	6th Floor Council Chambers
1.	Call meeting to order		
	Mayor V	Voodford called the meeting to order at 3:00pm	ъ.
2. Roll call of membership			
		 Public Works Director Vandehey, City Attor and Alderperson Doran Battalion Fire Chief Henson 	rney Behrens, Mayor Woodford
3.	Approval of minutes from previous meeting		
	21-1312 Minutes	s from August 2, 2021	
	Attachme	ents: Minutes 8-2-21.pdf	
		n was made by Attorney Behrens, seconded ey, that the minutes be approved. Roll Call. T g vote:	
	Aye: 4	 Public Works Director Vandehey, City Atto and Alderperson Doran 	rney Behrens, Mayor Woodford
	Excused: 1	- Battalion Fire Chief Henson	
4.	Public Hearings/Appearances		
5.	Action Items		
		Meade St. (31-1-8500-00) The Applica ct an athletic storage building with the s	

construct an athletic storage building with the stair riser height to be 8" and the tread depth to be 9". Section 4-136 of the Municipal Code (IBC 1011.5.2 of the Commercial Code) requires riser height to be a maximum of 7" and tread depth to be a minimum of 11".

Attachments: 5300 N. Meade St.pdf

Alderperson Doran moved, seconded by Public Works Director Vandehey, that the Report Action Item be approved. Roll Call. Motion carried by the following vote:

Aye: 4 - Public Works Director Vandehey, City Attorney Behrens, Mayor Woodford and Alderperson Doran

Excused: 1 - Battalion Fire Chief Henson

6. Information Items

7. Adjournment

A motion was made by Alderperson Doran, seconded by City Attorney Behrens, that this meeting was adjourned. The motion carried by the following vote:

Aye: 4 - Public Works Director Vandehey, City Attorney Behrens, Mayor Woodford and Alderperson Doran

Excused: 1 - Battalion Fire Chief Henson

Department of Public Works Return to: Inspection Division 100 North Appleton Street Appleton, Wisconsin 54911 (920) 832-6411

City of Appleton Application for Board of Building Inspection

Meeting Date:

Please write legibly and also submit a complete reproducible plan (maximum size 11" x 17"). A complete plan includes, but is not limited to, all structures, lot lines and streets with distances to each. There is a non-refundable \$45.00 fee for each variance application. The non-refundable fee is payable to the City of Appleton and due at the time the application is submitted.

Property Information				
Address of Property (Variance Requested) Parcel Number				
101 W. Edison Ave	31-4-0257-00			
Zoning District	Use 🗆 Residential X Commercial			
C2				

Applicant Information		
Owner Name	Owner Address	
Ament Enterprises LLC	W6442 Firelane 8	
	Menasha, WI 54952	
Owner Phone Number	Owner E Mail address (optional)	
Agent Name	Agent Address	
Mark Keating	500 North Commercial Street	
	Neenah, Wisconsin 54956	
Agent Phone Number	Agent E Mail address (optional)	
920-722-2445	mkeating@gries.design	

Variance Information Municipal Code Section(s) Project Does not Comply: Section 4-136 of the Municipal Code of the City of Appleton. SPS 362.0903(2) Automatic fire sprinkler systems.

Brief Description of Proposed Project

It is requested that a variance be granted to not install automatic sprinklers as required in the code section below for a space that will be used as an A-2 use group, where alcohol will be consumed.

IBC 903.2.1.2 Assembly Group A-2 requires an automatic sprinkler system where the fire area has an occupant load of 100 or more. Request is to omit the sprinkler system and the occupant load will be limited to 200 persons.

Owner's Signature (Required): _____ Date: _____